

CITY OF AUSTELL, GEORGIA

Addendum 1

For

Milling and Paving Cochran St, Rosehill St, Line St, Walker St, Cemetery St and Wilson St

ITB# 24-00008-PW

SUBJECT: Questions and Answers

Date: August 16, 2024

Q: How do we know what the City of Austell wants paved per each street? Will the streets be pre-marked?

A: Yes

Q: Who is responsible for manholes if they need additional work after milling around them?

A: The City

Q: Some of the street have speed bumps. Who is responsible replacing them?

A: The City

Q: There are 6 streets on the Section V. Will all streets be awarded? Or is it possible only certain street will be award due to budget issues?

A. All the streets will be awarded based on total lump sum price.

Q: I want to clarify we are only bidding on 2" Mill and 2" 12.5MM Asphalt. No asphalt patching or striping to be included in proposal pricing.

A: Yes, that is correct. NO patching or striping.

Q: Will sign mounted advanced warning signs be required or tripods will be enough?

A: Tripods will be enough

Q: Will side roads or driveways be required to be paved to the back of radius?

A: Will be milled/paved to where the pavement meets the driveway

Q: What is the milling cover up time requirement?

A: Seven (7) working days.

Q: Will the contractor be responsible of all material testing?

A: All testing will be the contractor's responsibility

Q: Will the contractor be allowed to park equipment within the ROW limits of the city or is it expected to mobilize in and out every day?

A: We have a place for it

Q: Will there be any shoulder grading work other than shoulder clipping?

A: No

Q: Are there any traffic loops within the roads? If so, is the contractor responsible for replacing these? If we are, please provide specifications and sizes.

A: There are none on those roads

Q: The streets appear to be much longer than the lengths provided in the bid package. Could the City please specify the start and end points for each section of each street to allow us to better understand the scope?

A: Streets are marked with arrows.

Q: Will the contractor be responsible for any shoulder rebuilding or grassing?

A: Only if they tear it up.

Q: Should the contractor assume riser rings or any other adjustment method for any manholes or water valves that may not currently be flush with the asphalt?

A: No

Q: Would the City want the millings from this project for future use? If so, does the City have an area where the millings can be disposed of or stockpiled?

A: No, Milling is the contractor's responsibility

Q: Due to current contractor backlog, two weeks for contract completion seems aggressive. Would the City consider extending the completion date for this project?

A: Three (3) weeks will be the maximum.

End of Addendum